



MW125

MCB 1P 3kA C-25A 1M

Technische Merkmale

Architecture

Number of protected poles	1
Number of poles	1 P
Type of pole	1 P
Curve	С

Connectivity

Bottom connection alignement for modular devices	Aligned terminal
Top connection alignement for modular devices	Aligned terminal

Main electrical features

Frequency		50/60 Hz
Rated short circuit breaking capacity Icn AC according IEC60898-1	illo	3 kA
Type of supply voltage		AC
Rated operational voltage LIe		230/400 V

Voltage

Rated insulation voltage	10	500 V
Rated impulse withstand voltage	500	4000 V

Electric current

3 kA
3 kA
3 kA
4,5 kA
5/10 ln
7/15 ln
1,13/1,45 ln
1,13/1,45 ln



Rating current -15°C 31 A Rating current 10°C 29.1 A Rating current 10°C 30.4 A Rating current 10°C 30.4 A Rating current 15°C 27.8 A Rating current 15°C 25.4 A Rating current 25°C 25.7 A Rating current 25°C 32.2 A Rating current 30°C 25.4 A Rating current 30°C 25.4 A Rating current 40°C 23.5 A Rating current 45°C 22.5 A Rating current 45°C 22.5 A Rating current 5°C 22.5 A Rating current 5°C 22.8 A Rating current 6°C 22.8 A Rating current 5°C	Electric current / temperature	
Rating current 10°C 29,1 A Rating current 10°C 30.4 A Rating current 15°C 26,4 A Rating current 20°C 26,4 A Rating current 25°C 25,7 A Rating current 25°C 32,2 A Rating current 30°C 25,8 A Rating current 30°C 24,2 A Rating current 40°C 23,5 A Rating current 45°C 22,7 A Rating current 5°C 28,5 A Rating current 5°C 28,8 A Rating current 5°C 29,8 A Rating current 5°C 21,8 A Rating current 5°C 20,8 A Rating current 6°C 20 A Rating current 6°C 20 A Rating current 6°C 20 A Rating current 5°C 13,3 A Correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 60 Hz 1 Correction factor of rating current for 3 devices placed side by-sid	Rating current -15°C	31 A
Rating current 10°C 27,8 A Rating current 10°C 30,4 A Rating current 10°C 27,1 A Rating current 20°C 26,4 A Rating current 25°C 25,7 A Rating current 30°C 32,2 A Rating current 30°C 25, A Rating current 30°C 24,2 A Rating current 40°C 23,5 A Rating current 45°C 22,7 A Rating current 5°C 28,5 A Rating current 5°C 28,5 A Rating current 5°C 29,8 A Rating current 5°C 21,8 A Rating current 5°C 21,8 A Rating current 5°C 20,8 A Rating current 5°C 21,8 A Rating current 5°C 19,3 A Rating current 5°C 11,8 A Current correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 400 Hz 1,2 Correction factor of magnetic tripping with 60 Hz 1 Correction factor of rating current for 2 devices placed side-by-side 0,95 Correction factor of rating current for 4 and 5 devices	Rating current -20°C	31,6 A
Rating current 15°C 27,1 A Rating current 26°C 26,4 A Rating current 25°C 25,7 A Rating current 25°C 32,2 A Rating current 30°C 25 A Rating current 35°C 24,2 A Rating current 40°C 23,5 A Rating current 45°C 22,7 A Rating current 45°C 28,5 A Rating current 50°C 29,8 A Rating current 50°C 29,8 A Rating current 50°C 20,8 A Rating current 50°C 19,3 A Correction factor of magnetic tripping with 400 Hz 1,5 <	Rating current 0°C	29,1 A
Rating current 15°C 27,1 A Rating current 20°C 26,4 A Rating current 25°C 32,2 A Rating current 30°C 25, A Rating current 30°C 24,2 A Rating current 30°C 24,2 A Rating current 40°C 23,5 A Rating current 45°C 28,5 A Rating current 5°C 28,5 A Rating current 5°C 29,8 A Rating current 50°C 21,8 A Rating current 50°C 21,8 A Rating current 60°C 20 A Rating current 60°C 20 A Rating current 70°C 18,4 A Current correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 400 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of rating current for 2 devices placed side-by-side 1 Correction factor of rating current for 3 devices 0,95 placed side-by-side 0,95 Correction factor of rating current for 6 devices placed side-by-side 0,85 Power 0,85	Rating current 10°C	27,8 A
Rating current 20°C 26,4 A Rating current 25°C 25,7 A Rating current 25°C 32,2 A Rating current 30°C 25 A Rating current 35°C 24,2 A Rating current 40°C 23,5 A Rating current 45°C 22,7 A Rating current 5°C 28,5 A Rating current 50°C 21,8 A Rating current 50°C 21,8 A Rating current 60°C 20 A Rating current 60°C 20 A Rating current 70°C 19,3 A Rating current 70°C 18,4 A Current correction factors 11,1 Correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 400 Hz 1 Correction factor of rating current for 2 devices 1 placed side-by-side 0,95 Correction factor of rating current for 3 devices 0,95 placed side-by-side 0,95 Correction factor of rating current for 4 and 5 0,9 devices placed side-by-side </td <td>Rating current -10°C</td> <td>30,4 A</td>	Rating current -10°C	30,4 A
Rating current 25°C 25,7 A Rating current 30°C 25 A Rating current 30°C 24,2 A Rating current 40°C 23,5 A Rating current 45°C 22,7 A Rating current 5°C 28,5 A Rating current 5°C 29,8 A Rating current 5°C 21,8 A Rating current 5°C 21,8 A Rating current 5°C 20 A Rating current 6°C 20 A Rating current 6°C 19,3 A Rating current 6°C 19,3 A Rating current 70°C 18,4 A Current correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 60 Hz 1 Correction factor of rating current for 2 devices placed side-by-side 0,95 Correction factor of rating current for 3 devices placed side-by-side 0,95 Power 0,85 Power loss per pole at In 3 W Total power loss under IN 3 W	Rating current 15°C	27,1 A
Rating current 30°C 25 A Rating current 30°C 25 A Rating current 35°C 242 A Rating current 40°C 23,5 A Rating current 45°C 22,7 A Rating current 5°C 29,8 A Rating current 5°C 21,8 A Rating current 50°C 21,8 A Rating current 60°C 20 A Rating current 60°C 20 A Rating current 70°C 19,3 A Rating current 70°C 18,4 A Current correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 60 Hz 1 Correction factor of rating current for 2 devices 1 placed side-by-side 0,95 Correction factor of rating current for 3 devices 0,95 placed side-by-side 0,95 Correction factor of rating current for 4 and 5 0,95 devices placed side-by-side 0,95 Correction factor of rating current for 6 devices 0,85 Power 0,90 Power loss p	Rating current 20°C	26,4 A
Rating current 30°C 25 A Rating current 40°C 23,5 A Rating current 40°C 23,5 A Rating current 45°C 28,5 A Rating current 5°C 29,8 A Rating current 5°C 21,8 A Rating current 50°C 21,8 A Rating current 60°C 20 A Rating current 65°C 19,3 A Rating current 70°C 18,4 A Current correction factors Current correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 400 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of rating current for 2 devices 1 placed side-by-side 0,95 Correction factor of rating current for 3 devices 0,95 placed side-by-side 0,95 Correction factor of rating current for 4 and 5 0,95 devices placed side-by-side 0,85 Correction factor of rating current for 6 devices 0,85 placed side-by-side 0,85 Power 0 <td>Rating current 25°C</td> <td>25,7 A</td>	Rating current 25°C	25,7 A
Rating current 40°C 23,5 A Rating current 40°C 22,7 A Rating current 45°C 22,7 A Rating current 5°C 28,5 A Rating current 5°C 28,5 A Rating current 5°C 29,8 A Rating current 5°C 21,8 A Rating current 60°C 20 A Rating current 60°C 19,3 A Rating current 70°C 18,4 A Current correction factors Current correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of rating current for 2 devices placed side-by-side 10,95 Correction factor of rating current for 3 devices placed side-by-side 0,95 Correction factor of rating current for 4 and 5 Correction factor of rating current for 4 and 5 Correction factor of rating current for 6 devices placed side-by-side 0,95 Correction factor of rating current for 6 devices placed side-by-side 0,95 Correction factor of rating current for 8 devices placed side-by-side 0,95 Correction factor of rating current for 8 devices placed side-by-side 0,95 Correction factor of rating current for 8 devices placed side-by-side 0,95 Correction factor of rating current for 8 devices placed side-by-side 0,95 Correction factor of rating current for 8 devices placed side-by-side 0,95 Correction factor of rating current for 8 devices placed side-by-side 0,95 Correction factor of rating current for 8 devices placed side-by-side 0,95 Correction factor of rating current for 9 devices placed 19 Au Correction factor of rating current for 9 Au Correction factor of rating cur	Rating current -25°C	32,2 A
Rating current 40°C 23,5 A Rating current 45°C 22,7 A Rating current 5°C 28,5 A Rating current 50°C 21,8 A Rating current 50°C 21 A Rating current 60°C 20 A Rating current 65°C 19,3 A Rating current 70°C 18,4 A Current correction factors Current or magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of rating current for 2 devices placed side-by-side 1 Correction factor of rating current for 3 devices placed side-by-side 0,95 Correction factor of rating current for 3 devices placed side-by-side 0,95 Correction factor of rating current for 6 devices placed side-by-side 0,95 Power Power loss per pole at In 3 W Total power loss under IN 3 W Total power loss under IN 3 W Total power loss under IN 3 W	Rating current 30°C	25 A
Rating current 45°C 22,7 A Rating current 5°C 28,5 A Rating current 5°C 29,8 A Rating current 50°C 21,8 A Rating current 50°C 21,8 A Rating current 50°C 21,8 A Rating current 60°C 20 A Rating current 60°C 20 A Rating current 60°C 319,3 A Rating current 70°C 318,4 A Current correction factors Current correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 60 Hz 1,5 Correction factor of rating current for 2 devices placed side-by-side 0,95 placed side-by-side 0,95 Correction factor of rating current for 3 devices placed side-by-side 0,95 Correction factor of rating current for 4 and 5 devices placed side-by-side 0,95 Power Power Power Power loss per pole at In 3 W Total power loss under IN 3 W Total power of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Rating current 35°C	24,2 A
Rating current 5°C 28,5 A Rating current 5°C 29,8 A Rating current 50°C 21,8 A Rating current 55°C 21,8 A Rating current 50°C 20,4 A Rating current 60°C 20,4 A Rating current 65°C 19,3 A Rating current 65°C 19,3 A Rating current 70°C 18,4 A Current correction factors Current correction factor of magnetic tripping with 100 Hz 1,1 C Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 60 Hz 1,5 Correction factor of rating current for 2 devices placed side-by-side 1,5 Correction factor of rating current for 3 devices placed side-by-side 0,95 placed side-by-side 0,9	Rating current 40°C	23,5 A
Rating current 5°C 29,8 A Rating current 50°C 21,8 A Rating current 55°C 21 A Rating current 60°C 20 A Rating current 65°C 19,3 A Rating current 65°C 19,3 A Rating current 65°C 19,3 A Rating current 70°C 18,4 A Current correction factors Correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 60 Hz 1,5 Correction factor of rating current for 2 devices placed side-by-side 0,95 placed side-by-side 0,95 Correction factor of rating current for 3 devices placed side-by-side 0,95 placed side-by-side 0,95 Correction factor of rating current for 6 devices placed side-by-side 0,95 Power Correction factor of rating current for 6 devices placed side-by-side 0,85 placed side-by-side 0,85 placed side-by-side 0,85 Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Rating current 45°C	22,7 A
Rating current 50°C 21,8 A Rating current 55°C 20 A Rating current 60°C 20 A Rating current 65°C 19,3 A Rating current 65°C 19,3 A Rating current 70°C 18,4 A Current correction factors Currection factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 60 Hz 1,5 Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 0,9 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Power Power Power Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Rating current 5°C	28,5 A
Rating current 55°C 21 A Rating current 60°C 20 A Rating current 60°C 19,3 A Rating current 65°C 19,3 A Rating current 70°C 18,4 A Current correction factors Currection factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 60 Hz 1,5 Correction factor of rating current for 2 devices 10,95 placed side-by-side 1,095 Correction factor of rating current for 3 devices 1,095 placed side-by-side 0,095 Correction factor of rating current for 4 and 5 1,095 Correction factor of rating current for 4 and 5 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 6 devices 1,095 Correction factor of rating current for 8 devices 1,095 Correction factor of rating current for 8 devices 1,095 Correction factor of rating current for 8 devices 1,095 Correction factor of rating current for 8 devices 1,095 Correction factor of rating current for 8 devices 1,095 Correction factor of rating current for 8 devices 1,095 Correction factor of rating current for 8 devices 1,095 Correction factor of rating current for 8 devices 1,095 Correction factor of rating current for 8 devices 1	Rating current -5°C	29,8 A
Rating current 60°C 19,3 A Rating current 65°C 19,3 A Rating current 70°C 18.4 A Current correction factors Correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 60 Hz 1,5 Correction factor of rating current for 2 devices placed side-by-side 0,95 Correction factor of rating current for 3 devices placed side-by-side 0,95 Correction factor of rating current for 4 and 5 0,95 Correction factor of rating current for 6 devices placed side-by-side 0,85 Correction factor of rating current for 3 devices 0,85 Correction factor of rating current for 3 devices 0,85 Correction factor of rating current for 3 devices 0,85 Correction factor of rating current for 3 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,85 Correction factor of rating current for 6 devices 0,95 Correction factor of rating current for 6 devices 0,95 Correction factor of rating current for 8 devices 0,95 Correction factor of rating current for 9 devices 0,95 Correction factor of rating current for 9 devices 0,95 Correction factor of rating current for 9 devices 0,95 Correction factor of rating current for 9 devices 0,95 Correction factor of rating current for 9 devices 0,95 Correction factor of rating current for 9 devices 0,95 Correction factor of rating current for 9 devices 0,95 Correction factor of rating current for 9 devices 0,95 Correctio	Rating current 50°C	21,8 A
Rating current 65°C 19,3 A Rating current 70°C 18,4 A Current correction factors Correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 60 Hz 1,5 Correction factor of rating current for 2 devices placed side-by-side 0,95 Correction factor of rating current for 3 devices 0,95 placed side-by-side 0,95 Correction factor of rating current for 4 and 5 0,95 devices placed side-by-side 0,85 Correction factor of rating current for 6 devices placed side-by-side 0,85 Power Power Power Power loss per pole at In 3 W Total power loss under IN 3 W Total power loss under IN 3 W Total power loss under IN 3 W Total power of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Rating current 55°C	21 A
Rating current 70°C 18,4 A Current correction factors Correction factor of magnetic tripping with 100 Hz 1,1 Correction factor of magnetic tripping with 200 Hz 1,2 Correction factor of magnetic tripping with 400 Hz 1,5 Correction factor of magnetic tripping with 60 Hz 1 Correction factor of rating current for 2 devices 1 placed side-by-side 1 Correction factor of rating current for 3 devices 1 placed side-by-side 1 Correction factor of rating current for 4 and 5 Correction factor of rating current for 4 and 5 devices placed side-by-side 1 Correction factor of rating current for 6 devices 1 Power Power Power Ioss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Rating current 60°C	20 A
Current correction factors Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Power Power Power loss per pole at In Total power loss under IN Total power loss under IN Substituting the side of the	Rating current 65°C	19,3 A
Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Power Power Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles A000 Number of mechanical operations Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Rating current 70°C	18,4 A
Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Power Power Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Current correction factors	
Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Power Power Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Correction factor of magnetic tripping with 100 Hz	1,1
Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Power Power Power loss per pole at In 3 W Total power loss under IN Sendurance Electric endurance in number of cycles Au000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm		
Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 0,9 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Power Power Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Correction factor of magnetic tripping with 400 Hz	1,5
placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 0,96 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Power Power Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm		
placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Power Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm		1
devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Power Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm		0,95
Power Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm		0,9
Power loss per pole at In 3 W Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm		0,85
Total power loss under IN 3 W Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Power	
Endurance Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Power loss per pole at In	3 W
Electric endurance in number of cycles 4000 Number of mechanical operations 20000 Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Total power loss under IN	3 W
Number of mechanical operations 20000 Dimensions 70 mm Depth of installed product 70 mm Height of installed product 83 mm	Endurance	
Dimensions Depth of installed product 70 mm Height of installed product 83 mm	Electric endurance in number of cycles	4000
Depth of installed product 70 mm Height of installed product 83 mm	Number of mechanical operations	20000
Height of installed product 83 mm	Dimensions	
Height of installed product 83 mm	Depth of installed product	70 mm
		83 mm
	Width of installed product	17,5 mm



Type of top connection for modular devices	with screw
Tightening torque	2,8Nm
Type of bottom rail clip for modular devices	metallic
Type of top rail clip for modular devices	NA
Type of Bottom Connection for modular devices	Blconnect
Bottom removability for modular devices	no
Top removability for modular devices	no
Connection	
Connection cross-sect. rigid cable	1 / 35mm²
Connection cross-sect. flexible conductor	1 / 25mm²
Type of connection	with screw
Connection cross section of access and exit with screws, for flexible conductor	1/25 mm²
Connection cross-section of input and output with screws, for massive conductors	1/35 mm²
Standards	
Standard text	EN 60898-1
European directive WEEE	concerned
Safety Protection index IP	IP20
Use conditions	29
Degree of pollution according to IEC 60664 / IEC 60947-2	2
00941-2	
Operating temperature	-25 70 °C
	-25 70 °C
Operating temperature	
Operating temperature Class of energy limitation I ² t	3
Operating temperature Class of energy limitation I²t Altitude	3 2000 m